

# Certificate of Conformity

By the product certificate number:

No. 250041RECO01-D-CER

Issued to:

License holder:

**Victron Energy B.V.**  
De Paal 35, 1351 JG, Almere, Netherlands

Trademark:



Contract number:

802190

It is certified that the product:

Type of product: Inverter/Charger with UPS functionality

Product Family: MultiPlus II - 3phase configuration

Models:	MultiPlus-II 48/8000/110-100 230V	MultiPlus-II 48/10000/140-100 230V	MultiPlus-II 48/15000/200-100 230V
Rated characteristics:			
Rated Power	8 kVA / 6.4 kW	10 kVA / 8 kW	15.0 kVA / 12.0 kW
Rated Voltage		AC input: 187-250 V <sub>ac</sub> DC input: 38-66 V <sub>dc</sub> AC output: 220-240 V <sub>ac</sub> DC output: 48 V <sub>dc</sub>	
Rated Frequency		50 / 60 Hz	
Firmware version	2621552	2627552	2619552
Number of phases		Three Phase <sup>(1)</sup> [3L/N/PE]	
Isolation transformer		Yes	

(1) The three-phase system consists of three individual inverters (of the same model) placed in parallel.  
(1) See on page 2 installation scheme.

Is in compliance with the standard:

- **G99/NI Issue 1, Amendment 1 (December 2023):** "Requirements for the connection of generation equipment in parallel with public distribution networks in Northern Ireland on or after 27 April 2019."<sup>(2)</sup>
- **G99 Issue 1, Amendment 10 (March 2024):** "Requirements for the connection of generation equipment in parallel with public distribution networks on or after 27 April 2019."<sup>(2)</sup>

<sup>(2)</sup> The Equipment Under Testing (EUT) is a Power Generating Unit without inertia, nonsynchronous, and it is certified that the above models indicated are in compliance with requirements detailed in the above referenced standards for grid connections of **Type A**.

This certificate is based upon test results offered in the test report No. 2222/0478-D-Amd2 issued on 22<sup>nd</sup> May 2024.

The above-mentioned generating unit is certified according to the SGS internal procedure PROCESO 4 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate is first issued on 19<sup>th</sup> February 2025.

This certificate is valid until the 19<sup>th</sup> February 2030.

Madrid, 19<sup>th</sup> February 2025.

Daniel Arranz Muñiz  
Certification Manager





**Installation scheme:**

